HENRY M. HIRATA
DIRECTOR

COUNTY OF SAN JOAQUIN
DEPARTMENT OF PUBLIC WORKS
P. O. BOX 1810 - 1810 EAST HAZELTON AVENUE
STOCKTON, CALIFORNIA 95201-1810
209/468-3000
FAX: 209/468-2999

THOMAS R. FLINN
DEPUTY DIRECTOR
MANUEL LOPEZ
DEPUTY DIRECTOR
STEVEN WINKLER
DEPUTY DIRECTOR

CERTIFIED
Z 166 517 984

September 23, 1998

Mr. Americo Laires
26276 East Magnolia Avenue
Escalon, California 95320

SUBJECT: COMPLETION OF DRIVEWAY FOR RESIDENCE AT 26276 EAST MAGNOLIA AVENUE

Dear Mr. Laires:

It has come to our attention that the driveway for the subject residence has not been completed as required by Encroachment Permit 98-108 SE, although the residence has been permitted occupancy.

To comply with San Joaquin County Ordinances and County Standard R-17, all new residential driveways within County road rights-of-way shall be surfaced with two inches of asphalt concrete over four inches of aggregate base or four inches of portland cement concrete. It is, therefore, requested that you pave the driveway approach within 30 days after receipt of this letter to comply with the Ordinances and Encroachment Permit. It is also requested that, prior to paving, you notify the Department of Public Works Field Engineering Division, at 468-3016 or return the card that was attached to the Permit for notification of inspection.

If you have any questions regarding this matter, please contact me at 468-3023.

Sincerely,

Gabriel Karam
GABRIEL KARAM
Senior Civil Engineer

GK:RH:ti
PS-81137.11A

E: Manuel Lopez, Deputy Director/Development

c: Jorge Gaspar, Engineering Assistant I