MATCH LINE SHEET 1

ARCO PM
18806 LWR. SAC. RD.
(NO GAS)

18826 LWR. SAC. RD.

OAKWOOD PROFESSIONAL CENTER
18815 LWR. SAC. RD.

LWR. SACRAMENTO RD

6" TP STL

DEACTIVATE 3" HP STL

115+00

116+00

117+00

118+00

119+00

120+00

INSTALL 539' OF 4" HPPPL

INSTALL:
(2) 4" PL TEE
(2) 4"x2" PL REDUCER

LEGEND

PROPOSED GAS MAIN
EXISTING GAS MAIN
REPLACE GAS SERVICE DIRECT BURIAL IN STREET INSERT ON PVT. PROP. IF POSSIBLE
EXISTING GAS SERVICE
EXISTING UNDERGROUND CATV
EXISTING UNDERGROUND ELECTRIC
EXISTING WATER MAIN
PROPOSED STORM DRAIN
EXISTING SANITARY SEWER
STORM DRAIN MANHOLE
PRESSURE CONTROL FITTING
REDUCER
ANODE
EXCESS FLOW VALVE
CUT OFF OLD MAIN
STREET LIGHT
FIRE HYDRANT
CATCH BASIN

RESIDENCES
18850 LWR. SAC. RD.
SR 3538

RESIDENCE
18854 LWR. SAC.
SR 4780

WOODBRIDGE INN
18878 LWR. SAC. RD.
SR 2495

BANK OF LODI
18853 LWR. SAC. RD.

WOODBRIDGE PIZZERIA
18819 LWR. SAC. RD.

INSTALL:
2" BOTTOM PCF
2" STL ELBOW
2"x2" TRANS
2" STL CAP
C/O OLD MAIN
INSTALL E.T.S.:
SEE DETAIL

IF SVC IS NOT REPLACED BY INSTERT, THEN REPLACE WITH 1" HPPL

2" HP STL

DEACTIVATE 2" HP STL

INSTALL 112' OF 2" HPPL

AGUSTA ST.

PROJECT BOUNDARY

INSTALL:
2" PL ELBOW

CALIFORNIA WASTE RECOVERY SYSTEMS

18921

HAIR MILL & CO.

WOOD-BRIDGE HARRD-WOOD CO.
SR 2496

DEACTIVATE 3" HP STL

18939
WOODBRIDGE FEED & FUEL

INSTALL 197' OF 2" HPPL MAIN

DE-ACTIVATE EXIST. 2" HP STL

INSTALL:
2" PL CAP

RESIDENCE
1201 AGUSTA ST.

EXIST. 6" TP STL

NOTE:
ON COMMERCIAL SERVICES WHEN EXISTING 3/4" STL SVC CAN NOT BE INSERTED WITH 1/2" HPPL, THEN RE-RUN SVC WITH 1" HPPL.

PLEASE CALL U.S.A. AT LEAST 48 HOURS PRIOR TO EXCAVATING IN THIS AREA
1-800-227-2600
TICKET # _____
DATE CALLED _____

MAP: 2869-B7,B8,C7
CPA: 286901
TBA: X-05
MAOP: 60 PSIG
E.S.ZONE: 16-LO-01-B

RESIDENCE
18934 LWR. SAC. RD.

MATCH LINE SHEET 3

REPLACE GAS MAIN & SERVICES
LOWER SACRAMENTO ROAD FROM MOKELUMNE ST. TO W.I.D. CANAL
WOODBRIDGE UNINC. - S.J. COUNTY

NO.	DATE	DESCRIPTION	ORDER #	DWN	CHKD	SUPV	APVD	BY
		REVISIONS						

EST: JG HOUBEIN
ADE: RD GIBBS
SUPV: AM D'ALESSANDRO
REP: DC RYMERS
PLNR: DC RYMERS
SCALE: 1"=20' DATE: 8/9/04

ENGINEERING AND PLANNING DEPT.
4040 WEST LANE
STOCKTON, CA 95204
PHONE #: (209) 942-1498 FAX #: (209) 92-1737
PACIFIC GAS AND ELECTRIC COMPANY

CO:
SD:
NOTIF.: 101344902
Other: DWG. 2 OF 3
SHT: 23 OF 24 SHEETS
PM: 30375641
REV.